

10 August 1971

MEMORANDUM FOR

STATINTL

SUBJECT

1. It is requested that the Operating Engineers keep close control over the water temperatures in the house air-conditioning system, and the 125 ton unit.

STATINTL

2. When the Room is being cooled off the house air-conditioning chilled water system and the temperature of this water system rises above 46 degrees, the Room must be switched to the 125 ton chilled water system.

STATINTL

STATINTL

Distribution:

Orig. and 1-adse

1-GSA, AGF, Bldgs. Mngr

2-NPIC/SS/LB/EMS

(10 Aug. '71)

STATINTL

Declass Review by NIMA/DOD